

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product

Produit

Independent controlgears

Name and address of the Applicant

Nom et adresse du demandeur

Mean Well Enterprises Co., Ltd.

No.28, Wuquan 3rd Road, Wugu Dist, New Taipei City 248

Taiwan

Name and address of the manufacturer

Nom et adresse du fabricant

Mean Well Enterprises Co., Ltd.

No.28, Wuquan 3rd Road, Wugu Dist, New Taipei City 248

Taiwan

Name and address of the factory

Nom et adresse de l'usine

Mean Well (Guangzhou) Electronics Co., Ltd.

2F, A Building, Yuean Industrial Park, Huangcun, Dongpu Town, Tianhe District, Guangzhou,

Guangdong

China

Rating and principal characteristics

Valeurs nominales et caractéristiques principales

Class I, ta: 60 °C, tc: 90 °C, λ: 0,95, SELV Independent controlgears, Inherently short-circuit proof, 110 °C thermal protection; MM mark,ELG-100-CXY (X=1050, 1400, Y=blank, A, B, AB, D, D2, DA, ADA, AD2): Constant current.ELG-100-XY (X=24, 36, 42, 48, 54, Y=blank, A, B, AB, D, D2,DA, ADA, AD2): Constant voltage.IP65 for model ELG-100-CXY (X=1050, 1400, Y=A, AB, ADA, AD2), ELG-100-XY (X=24, 36, 42, 48, 54, Y=A, AB, ADA, AD2)IP67 for model ELG-100-CXY (X=1050, 1400, Y= blank, B, D, D2, DA), ELG-100-XY (X= 24, 36, 42, 48, 54, Y= blank, B, D, D2, DA)(Details refer to general product information of test report)

Trademark (if any)

Marque de fabrique (si elle existe)



Type of manufacturer's Testing Laboratories used

Type de programme de laboratoire d'essais constructeur

Model / Type Ref.

Réf. de type

ELG-100-CXY (X=1050, 1400, Y=blank, A, B, AB, D, D2, DA, ADA, AD2)

ELG-100-XY (X= 24, 36, 42, 48, 54, Y=blank, A, B, AB, D, D2, DA, ADA, AD2)

Additional information (if necessary may also be reported on page 2)

Les informations complémentaires (si nécessaire, peuvent être indiquées sur la 2ème page)

A sample of product was tested and found to be in conformity with IEC

Un échantillon de ce produit a été essayé et été considéré conforme à la CEI

61347-1(ed.2);am1;am2

61347-2-13(ed.2)

National differences / Comments

Les différences nationales / Commentaires

EU Group Differences, AU, NZ

This CB Test Certificate is issued by the National Certification Body:

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands



Date: 2015-08-28

Signature: Rosa Zhou



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES
FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS
DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

As shown in the test report Ref. No. which forms part of this
certificate

4323568.50

Comme indiqué dans le rapport d'essais numéro de référence
qui constitue partie de ce certificat

This CB Test Certificate is issued by the National Certification Body:

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands



Date: 2015-08-28

Signature: Rosa Zhou



Additional factory

Mean Well Enterprises Co., Ltd.

No.28, Wuquan 3 rd, Wugu Dist, New Taipei City 248

Taiwan

Suzhou Mean Well Technology Co., Ltd.

No. 77, Jian-min Road, Dong-qiao, Pan-yang Ind. Park, Huang-dai Town,
Xiang-cheng Dist, Suzhou, 215152 Jiangsu

China

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Ce Certificat d'essai OC est établi par l'Organisme National de Certification



Date: 2015-08-28

Signature: Rosa Zhou

